



«УТВЕРЖДАЮ»

Председатель экспертно-
технической комиссии

ООО «Шуртанский ГХК»

 X. Аллаёров

« 04 » 12 2020 г.



Рег. № 074/ _____

Техническое задание
на закупку двухдисковой полнопроходной задвижки
для нужд ООО «Шуртанский ГХК»

ШГХК 2020 г.

1. ОБЩИЕ СВЕДЕНИЯ

1.1 Наименование и характеристика

Двухдисковая полнопроходная задвижка (металлические уплотнения) с электроприводом.
Размер 18" # класс ANSI 150.

Двухдисковая полнопроходная задвижка (металлические уплотнения) размер 12" # класс ANSI 150.

Двухдисковая полнопроходная задвижка (металлические уплотнения) размер 8" # класс ANSI 150.

TAG-Number	XV-11108 XV-11208 XV-11308	XV-11117 XV-11217 XV-11317
Application:	Ethylene service, transfer line block valve	Ethylene service, Decoke Valve.
Valve type:	Double Disc Through Conduit Type Gate Valve (steel-welded body design)	Double Disc Through Conduit Type Gate Valve (steel-welded body design)
Size:	DN18"	DN 8"
Quantity / количество:	3set/ комплекта.	3set/ комплекта.
Face to face:	650mm.	400mm.
End connection:	Flanged end	Flanged end
End connections:	Flanged ends to ANSI B 16.5 class 150#, RF.	Flanged ends to ANSI B 16.5 class 150#, RF.
O.D. of flange:	635mm	343mm
B.C.D. of flange:	577.8mm	298.4mm
Number of bolt holes:	16	8
Diameter of bolt holes:	32mm	22mm
Flange thickness (acc/ to design conditions):	40mm	29.5mm
Stroke:	550mm.	230mm.
Overall Length of valve:	approx. 5007mm.	
Total number of purge steam connections:	4	2
Total number of purge steam connections:	DN 11/2", 150# ANSI B 16.5.	
Size and class of purge steam connections:	DN 11/2"	DN3/4"
Electronic Actuator.	Data sheet attached	Data sheet attached
Operating characteristics		
Operating environment	Pyrolysis gas	Pyrolysis gas
Pyrolysis gas working pressure	46 kPa	46 kPa
Pyrolysis gas operating temperature	210°C	210°C
TAG-Number	XV-11107,XV-11207,XV-11307	
Application:	Ethylene service, Decoke Valve.	
Valve type:	Double Disc Through Conduit Type Gate Valve (steel-welded body design)	
Size:	DN12"	
Quantity / количество:	3set/ комплекта.	
Face to face:	500mm.	
End connections:	Flanged ends to ANSI B 16.5 class 150#, RF.	
O.D. of flange:	482.6mm	

B.C.D. of flange:	431.8mm	
Number of bolt holes:	12	
Diameter of bolt holes:	26mm	
Flange thickness (acc/ to design conditions):	32mm	
Stroke:	410mm.	
Overall Length of valve:	approx. 2975mm.	
Total number of purge steam connections:	2	
Total number of purge steam connections:	DN 11/2", 150# ANSI B 16,5.	
Electronic Actuator.	Data sheet attached	Data sheet attached

Operating characteristics

Operating environment	Pyrolysis gas	Pyrolysis gas
Pyrolysis gas working pressure	46 kPa	46 kPa
Pyrolysis gas operating temperature	210°C	210°C

1.2 Основание и цель приобретения материала

Основание: годовая заявка на 2020год.

Цель: Для восстановления работоспособности и обеспечения дальнейшей надежной эксплуатации печей пролиза ВА-1101, ВА-1102, ВА-1103.

1.3 Сведения о новизне

Поставляемый товар должен быть новым, не ранее 2020 года выпуска (который не был в употреблении, в том числе не был восстановлен, у которого не были восстановлены потребительские свойства).

1.4 Этапы разработки / изготовления

Предлагаемое оборудование должно быть предварительно согласовано с Заказчиком, для этого следует предоставить:

- конструкционный чертёж задвижек, включая чертеж приводов;
- материалы изготовления задвижек.

2. ОБЛАСТЬ ПРИМЕНЕНИЯ

Печи пиролиза ВА-1101, ВА-1102 и ВА-1103 предназначены для получения пирогаза методом термического разложения углеводородного сырья.

Запорно-отсекающие арматуры (двуходисковые полнопроходные задвижки) предназначены для проведения контроля процесса пиролиза в печах ВА-1101, ВА-1102, ВА-1103, с установленной автоматической системы контроля последовательности операций. С помощью данной системы проводится управление электрическим приводом, запорными отсечными задвижками, автоматическим сбросом и подъемом давления.

3. УСЛОВИЯ ЭКСПЛУАТАЦИИ

3.1 Общие условия эксплуатации

Режим работы печей пиролиза ВА-1101, ВА-1102 и ВА-1103 – непрерывный.

Установка ГСЭУ останавливается на ремонт 1 раз в год на 18 суток.

Печи пиролиза установлены на открытой площадке с температурой окружающего воздуха -20 +60°C.

Декоксование ведется при температуре 810–860°C на выходе из змеевиков печи, с подачей паровоздушной смеси в змеевик.

Применяемый ингибитор коксообразования: Диметилдисульфид (ДМДС) C₂H₆S₂.

При декоксования или выжиге кокса образуются оксиды углерода (CO и CO₂).

4. ТЕХНИЧЕСКИЕ ТРЕБОВАНИЯ

4.1 Основные технические требования

4.1.1. Двухдисковые полнопроходные задвижки должны быть специально разработаны для гарантированного и герметичного отсечения технологического потока в условиях коксования седел и затвора. (Необходимо описать механизм, предупреждающий заклинивание рабочих органов).

4.1.2. Двухдисковые полнопроходные задвижки должны обеспечивать надежную работу в следующих случаях:

- Высокие температуры;
- Температурные изменения;
- Перепады температур;
- Трубопроводные напряжения;
- Частые срабатывания;
- Короткое время закрытия;
- Высокое дифференциальное давление;
- Должны быть рассчитаны для всех сред, содержащих твердые и коксующиеся вещества.

4.1.3. Конструкция двухдисковых полнопроходных задвижек должна обеспечить возможность разбора и ревизии рабочих органов по месту эксплуатации.

4.1.4. Предусмотреть в конструкции (показать на чертеже и описать в технической спецификации):

- Механизм двойного параллельного независимого затвора с усиленной поверхностью;
- Параллельные независимые усиленные уплотнения затвора;
- Система блокировки от попадания в корпус частиц технологического потока;
- Осевой компенсатор;
- Систему поглощения избыточного крутящего момента;
- Детектор положения рабочих органов;
- Систему динамической нагрузки сальниковой камеры;
- Механический распределитель прижимного усилия на затвор;
- Фиксированные на корпусе упорные клинья системы механического разжатия.
- Направляющие пластины скольжения;
- Систему очистки корпуса, механического распределителя прижимного усилия, упорных клиньев и осевого компенсатора (предоставить модель работы системы очистки);

4.1.5. Не допускается:

Конструкция крана с зауженной проточной частью;

Конструкция крана с цельным односоставным запорным органом;

Конструкция затвора без механизма разжатия;

Конструкция разжатия затвора подвижным разборным шарика-клиновым механизмом;

Использование интегрированных и несъемных седел;

Использование мягких и деформируемых уплотнений между седлами и затвором;

4.1.6. Конструкция двухдисковых полнопроходных задвижек должна быть рассчитана на не менее 150 000 циклов срабатывания без профилактического обслуживания.

4.2 Требования по надежности

Материалы основных деталей двухдисковые полнопроходные задвижки, в том числе уплотнительных элементов, должны быть устойчивыми к деформации, истиранию, разрушению по отношению к рабочей среде и устойчивы к условиям эксплуатации, указанных в разделе 1.1.

Срок службы не менее 10 год.

4.3 Требования к маркировке

Маркировка должна соответствовать требованиям государственных стандартов Республики Узбекистан, не противоречащим и не уступающим международным общепринятым стандартам. Маркировка товара должна содержать расшифрованное наименование оборудования, наименование изготовителя, адрес места нахождения изготовителя, дату выпуска и другую необходимую информацию.

На задвижках должна быть маркировка с указанием:

- материалов изготовления;
- номинального диаметра;
- класса давления;
- страны производителя;
- серийного номера двухдисковой полнопроходной задвижки.

4.4 Требования к ЗИП и быстроизнашивающимся деталям

Предоставить сведения по частоте ремонтов двухдисковых полнопроходных задвижек и необходимых для этого комплектов ЗИП.

5. ТРЕБОВАНИЯ ПО ПРАВИЛАМ СДАЧИ И ПРИЕМКИ

5.1 Порядок сдачи и приемки

Приемка и входной контроль Продукции соответствия количеству, качеству и размерам выполняется на складе Заказчика. В случае несоответствия поставляемого товара с заказной спецификацией или если товар не прошел входной контроль качества, Поставщик обязан заменить его в течение срока, указанного в договоре. Транспортные расходы при замене товара берет на себя Поставщик товара.

5.2 Требования по передаче заказчику технических и иных документов при поставке оборудования

Для подтверждения новизны оборудования поставщик в обязательном порядке должен на момент поставки представить следующие документы подтверждающие новизну, качество и соответствие техническому заданию предлагаемого к поставке оборудования:

- копию сертификата соответствия (действительного на момент проведения торгов) подтверждающего соответствие требованиям нормативным документам;
- образцы гарантийных талонов.

Исполнитель гарантирует Заказчику, что приобретенное им оборудование соответствует техническим характеристикам оборудования, заявленным заказчиком данного оборудования. Необходимо предоставить Сертификаты материалов с указанием химического анализа и прочностных характеристик. Необходимо предоставить Сертификаты соответствия материала. Предоставить сертификаты качества производителя в объеме технического предложения. Указать место и страну выпускемого продукта.

6. ТРЕБОВАНИЯ К ТРАНСПОРТИРОВАНИЮ

Условия транспортировки должны обеспечивать сохранность продукции, габариты из расчета возможностей транспортировки до склада получателя.

7. ТРЕБОВАНИЯ К ОБЪЕМУ И/ИЛИ СРОКУ ПРЕДОСТАВЛЕНИЯ ГАРАНТИЙ

Поставщик предоставляет гарантию качества на товар в соответствии с гарантией завода-производителя.

Обязательным условием является предоставление гарантии от износа узлов предлагаемого оборудования с заменой и ремонтом всего оборудования или его составных частей не менее 36 месяцев эксплуатации, независимо от причины выхода из строя (при условии эксплуатации в заявленных режимах согласно ТЗ).

Такой ремонт или замена должны осуществляться неограниченное количество раз за счет поставщика оборудования в течение всего периода действия эксплуатационной гарантии.

Двухдисковые полнопроходные задвижки с противопожарной защитой должны пройти испытание в соответствии с требованиями API - 607 / 6A.

8. ТРЕБОВАНИЯ К КАЧЕСТВУ И КЛАССИФИКАЦИИ

Товар должен быть качественным и отвечающим предъявляемым к нему требованиям назначения, имеющим необходимые потребительские свойства и технические характеристики, характеристики экологической и промышленной безопасности. Качество товара должно подтверждаться сертификатом качества, выданного на заводепроизводителя. Поставщик также несет ответственность за соответствия технических параметров и за качество. В случае несоответствия продукции требованиям по качеству, продукция подлежит возврату, а все затраты по её приобретению и доставке ложатся на Поставщика.

9. ТРЕБОВАНИЯ К КОЛИЧЕСТВУ, КОМПЛЕКТАЦИИ, МЕСТУ И СРОКУ (ПЕРИОДИЧНОСТИ) ПОСТАВКИ

Количество оборудования указано в пункте 1.1

Срок поставки: до 01.04.2021 года.

Условия поставки согласно базису поставки DAP. Единоразовая поставка в полном объеме.

Место поставки:

DAP - Республика Узбекистан, Кашкадарьянская область, Гузарский район, п. Шуртан, 180300.

10. ТРЕБОВАНИЕ К ФОРМЕ ПРЕДСТАВЛЯЕМОЙ ИНФОРМАЦИИ

Текстовая информация должна предоставляться на русском и/или английском языках, в бумажном и электронном варианте (1 экземпляр).

11. ПЕРЕЧЕНЬ ПРИНЯТЫХ СОКРАЩЕНИЙ

№ п/п	Сокращение	Расшифровка сокращения
1	ТЗ	Техническое задание
2	ГСЭУ	Горячая секция этиленовой установки


12. ПЕРЕЧЕНЬ ПРИЛОЖЕНИЙ

№ п/п	Наименование приложения	Номер страницы / Количество листов
1	Чертёж существующих двухдисковых полнопроходные задвижек прилагаются.	3 лист.


*Примечание: За правильность заполнения и незаполненные пункты ответственность несёт разработчик.

Разработчики:

Заместитель главного механика:

 **M. Салаев**

Инженер ОГМ:

 **Ф. Ботиров**


Ведущей инженер СУМР и Р:

 **Г. Рахманов**

Начальник ЦПЭ:

 **О. Муртазаев**

Старший механик ЦПЭ:

 **Ф. Нурматов**

Бош метролог

 **Х. Махмудов**


Механик по печи:

 **Б. Аминов**



TECHNICAL SPECIFICATION (DATA SHEET)


ELECTRIC MOTORS FOR LOW-VOLTAGE
MOTOR OPERATED VALVES

Client :	ABB Group Consortium			Always refer to this number			
Plant :	SHURTAN GAS CHEMICAL COMPLEX			G 09 04	10162	6210	
Location :	Shurtan, Republik of Uzbekistan			Orig.	Dept.	Div.	
Unit :				Job	REQ. / POR	Rev.	
Date :				Attachment No.:			
Page: 1 of 1							
TAG-NO.: XV-11107 / 11207 / 11307							
1	<input checked="" type="checkbox"/> Type	MX	Regulations:		Item No.	Unit	
2	<input checked="" type="checkbox"/> Size	10	VDE/DIN	VIK	Operation		
3	<input checked="" type="checkbox"/> Manufacturer		IEC	NEMA	Standby		
4			SPEC. 1-0162-N-703				
5	CONNECTION		LOCATION				
6	<input checked="" type="checkbox"/> Direct	Outdoor	X	Elevation < 1000m			
7	Star-Delta	Indoor		Elevation > 1000m			
8	<input checked="" type="checkbox"/> Starter	1473	X Corrosive Atmosphere	X Ambient Temperature	+49 / -27	°C	
9	<input checked="" type="checkbox"/> Adjustable Speed	N/A		X Design Temperature	+40 / -20	°C	
10	TECHNICAL DATA						
11	<input checked="" type="checkbox"/> Req. Power at Shaft	N/A	kW	<input checked="" type="checkbox"/> Starting Current	I _A / I _N	6.5 A	
12	<input checked="" type="checkbox"/> Rated Output	35	kW	<input checked="" type="checkbox"/> Starting Torque	M _A / M _N	9.0 %	
13	<input checked="" type="checkbox"/> Speed	1425/min	1/min	<input checked="" type="checkbox"/> Breakdown Torque	M _K / M _N	N/A	
14	X Voltage (3 Phase)	380	V + / -	5 %	X Start up Time with Load	s	
15	X Frequency	50	Hz + / -	2 %	t _E - Time (for Ex e only)	s	
16	<input checked="" type="checkbox"/> Rated Current	FLA-2.0/LRA-6.5	A	<input checked="" type="checkbox"/> Mass Moment of Int. (J)		N/A kgm ²	
17	<input checked="" type="checkbox"/> Power Factor cosφ (load 100%)	0.46		<input checked="" type="checkbox"/> Dimension Drawing No.		N/A	
18	Power Factor cosφ (load 75%)			<input checked="" type="checkbox"/> PTB/Cert. of Conformity		N/A	
19	<input checked="" type="checkbox"/> Efficiency η (load 100%)	0.59					
20	Efficiency η (load 75%)						
21	MOTOR SPECIFICATION						
22	X Type of Rotor	X Squirrel Cage	Wound	<input checked="" type="checkbox"/> E Mounting (viewed to shaft)		N/A	
23	<input checked="" type="checkbox"/> Type of Construction	EEXD IIC		<input checked="" type="checkbox"/> L × Type of Cable		SWA	
24	X Degr. of Protect. Mot./Term. Box	IP 68	/ IP 68	<input checked="" type="checkbox"/> o Cablediameter	(LATER)	mm	
25	X Explosion proof Classification	Ex de IIIB CT5		<input checked="" type="checkbox"/> L □ Cable-Entry		1xM42 + 2xM32	
26	X Insulation Class/Limit of Temp.rise	F / B		<input checked="" type="checkbox"/> M Make		N/A	
27	<input checked="" type="checkbox"/> Vibration (accord. to ISO 2373)	N R S		<input checked="" type="checkbox"/> T Type		BALL	
28	X Restart on residual Voltage	100	%	<input checked="" type="checkbox"/> N Normal / Reinforced			
29	<input checked="" type="checkbox"/> Statorwinding Connection	Delta (if possible)	WYE	<input checked="" type="checkbox"/> L Lubrication		PERMANENT	
30	X Direction of Rotation	Bi-directional		<input checked="" type="checkbox"/> R Re-Lubrication Device (*2)		N/A	
31	X Mode of Operation (Duty)	S2		<input checked="" type="checkbox"/> W Winding Temp. sensor (*3)			
32	<input checked="" type="checkbox"/> Rotor Class	N/A		<input checked="" type="checkbox"/> O Motor Space Heater (220V, 1Ph)		10 W	
33	<input checked="" type="checkbox"/> Rotor Weight	N/A kg		<input checked="" type="checkbox"/> O Sound Power Level (L _{WA}) (*1)	N/A	dB (A)	
34	<input checked="" type="checkbox"/> Total Weight	N/A kg		<input checked="" type="checkbox"/> O Sound Pressure Level (L _{PA}) (*1)	N/A	dB (A)	
35	X Ext. Grounding Terminal	- min. M10 thread size		Vibration Monitoring			
36	X Painting Corrosion Resistant			Bearing Temp. Sensor			
37				<input checked="" type="checkbox"/> X Accessories			
38	DRIVEN EQUIPMENT						
39	<input checked="" type="checkbox"/> Compressor	<input checked="" type="checkbox"/> Make					
40	<input checked="" type="checkbox"/> Pump	<input checked="" type="checkbox"/> Supplier					
41	<input checked="" type="checkbox"/> Fan	<input checked="" type="checkbox"/> Torque Characteristic					
42	<input checked="" type="checkbox"/> MOV	<input checked="" type="checkbox"/> Total external Moment of Inertia (J)					kgm ²
43	COUPLING						
44	Direct	Type					
45	X Gear	X Supply	X Machine Manufacturer	Motor Manufacturer			
46	V-Belt	X Mounting	X Machine Manufacturer	Motor Manufacturer	Jobsite		
47							
48	REMARKS: X = Requirements	O = to be filled in by Bidder/Supplier	/ = not applicable				
49	(*1) : max closing time of Valve						
50	(*2) : Mov-Actuator equipped with intergrated motorstarter for two directions and thermal overload relais						
51	intergrated logic						
52	terminals and box for external control for multicore-signalcable						
53	intergrated Local Control Station : open/close/stop/remote/local/off						
54	indication open/close/failure						
55	Powercable	Signalcable					
56	Prepared: H. Schneider	Date: 16.06.99	Checked: RL	Rev. /	Rev. /	Rev. /	




TECHNICAL SPECIFICATION (DATA SHEET)


ELECTRIC MOTORS FOR LOW-VOLTAGE
MOTOR OPERATED VALVES

Client :	ABB Group Consortium			Always refer to this number		
Plant :	SHURTAN GAS CHEMICAL COMPLEX			G 09 04	10162	6210
Location :	Shurtan, Republik of Uzbekistan			Orig.	Dept.	Div.
Unit :				Job	REQ. / POR Rev.	
Date :				Attachment No.:		
Page: 1 of 1						
TAG-NO. : XV-11108 / 11208 / 11308						
1 <input type="radio"/> Type	MX	Regulations		Item No.	Unit	
2 <input type="radio"/> Size	40	VDE/DIN	VIK	Operation		
3 <input type="radio"/> Manufacturer		X IEC	NEMA	Standby		
4		X SPEC. 1-0162-N-703				
5	CONNECTION			LOCATION		
6 X	Direct	X Outdoor		X Elevation < 1000m		
7	Star-Delta	Indoor		Elevation > 1000m		
8 O Starter	1473	X Corrosive Atmosphere		X Ambient Temperature	+49 / -27	°C
9 O Adjustable Speed	N/A			X Design Temperature	+40 / -20	°C
10	TECHNICAL DATA					
11 O Req. Power at Shaft	N/A	kW	O Starting Current I_A / I_N	24.0 A		
12 O Rated Output	1.8	kW	O Starting Torque M_A / M_N	23.0 #		
13 O Speed	2800/min	1/min	O Breakdown Torque M_K / M_N	N/A		
14 X Voltage (3 Phase)	380 V	+/- 5 %	X Start up Time with Load	s		
15 X Frequency	50 Hz	+/- 2 %	t_E - Time (for Ex e only)	s		
16 O Rated Current	FLA-5 0/LRA-24.0	A	O Mass Moment of Int. (J)	N/A kgm ²		
17 O Power Factor cosφ (load 100%)	.71		O Dimension Drawing No.	N/A		
18 O Power Factor cosφ (load 75%)			O PTB/Cert. of Conformity	N/A		
19 O Efficiency η (load 100%)	.76					
20 O Efficiency η (load 75%)						
21	MOTOR SPECIFICATION					
22 X Type of Rotor	X Squirrel Cage	Wound	O E	Mounting (viewed to shaft)	N/A	
23 O Type of Construction	EXED IIC			X	Type of Cable	SWA
24 X Degr. of Protect. Mot./Term. Box	IP 68	/	IP 68	X	Cable diameter	(LATER) mm
25 X Explosion proof Classification	Ex de IIIB CT5			X	Cable-Entry	1xM42 + 2xM32
26 X Insulation Class/Limit of Temp.rise	F / B		O	Make	N/A	
27 O Vibration (accord. to ISO 2373)	N	R	S	O	Type	BALL
28 X Restart on residual Voltage	100 %			O	Normal / Reinforced	
29 O Statorwinding Connection	Delta (if possible) WYE			O	Lubrication	PERMANENT
30 X Direction of Rotation	Bi-directional			X	Re-Lubrication Device (*2)	N/A
31 X Mode of Operation (Duty)	S2				Winding Temp. sensor	(*3)
32 O Rotor Class	N/A			O	Motor Space Heater (220V, 1Ph)	W
33 O Rotor Weight	N/A kg			O	Sound Power Level (L_{WA})	(*1) N/A / dB (A)
34 O Total Weight	N/A kg			O	Sound Pressure Level (L_{PA})	(*1) N/A / dB (A)
35 X Ext. Grounding Terminal	min. M10 thread size			Vibration Monitoring		
36 X Painting Corrosion Resistant				Bearing Temp. Sensor		
37				X	Accessories	
38	DRIVEN EQUIPMENT					
39 O Compressor	O Make					Motor viewed to Shaft 
40 O Pump	O Supplier					
41 O Fan	O Torque Characteristic					
42 X MOV	O Total external Moment of Inertia (J)					
43	COUPLING					
44 Direct	Type					
45 X Gear	X Supply	X Machine Manufacturer	Motor Manufacturer			
46 V-Belt	X Mounting	X Machine Manufacturer	Motor Manufacturer	Jobsite		
47						
48 REMARKS: X = Requirements	O = to be filled in by Bidder/Supplier	/ = not applicable				
49 (*1) : max closing time of Valve						
50 (*2) : Mov-Actuator equipped with:	integrated motorstarter for two directions and thermal overload relays					
51	integrated logic					
52	terminals and box for external control for multicore-signalcable					
53	integrated Local Control Station: open/close/stop/remote/local/off					
54	indication open/close/failure					
55 Powercable:	Signalcable					
56 Prepared: H. Schneider Date: 16.06.99	Checked: RL	Rev. /	Rev. /	Rev. /	Rev. /	Rev. /





SECTION "A-A"



TIV18[®] SDVB[®]
 TAG-NR.: XV 11108 XV 11117
 XV 11208 XV 11217
 XV 11308 XV 11317

FLUID
 PROCESS - DECOCKING: HYDROCARBONS WITH STEAM
 AND OIL-COKE PARTICLES
 FLOW RATE: 15.500 kg/hr

OPERATING PRESSURE: 250 kPaG
 OPERATING TEMPERATURE: 270°C

DESIGN PRESSURE: 350 kPaG
 DESIGN TEMPERATURE: 425°C

STEAM PURGE
 OPERATING PRESSURE: 400 kPaG
 OPERATING TEMPERATURE: 190°C


DESIGN PRESSURE: 400 kPaG
 DESIGN TEMPERATURE: 280°C

CORROSION ALLOWANCE:
 MEDIUM WETTED PARTS: 1/8" (3mm)
 (BODY PASSAGE)
 PURGE STEAM WETTED PARTS: 1/16" (1.5mm)
 (BODY CAVITY)
 THE PURGE STEAM SHOULD BE THROTTLED TO 0.5 barg
 ABOVE OPERATING/DECOOKING PRESSURE TO PURGE THE VALVES
 INSTALLATION: VERTICAL STEM IN HORIZONTAL LINE




EXTERNAL LOADS: 8" VALVE

N	IN	OUT	Nm	M
Fx	-4000	4000	Mx	3000
Fy	5000	5000	My	3000
Fz	4000	-4000	Mz	1000



BILL OF MATERIAL

ITEM	REQ'D	DESCRIPTION	MATERIAL	REFERENCE
1	1	18" VALVE ASSEMBLY	STL.	SAS16-CR.70/SA-105
2	1	8" VALVE ASSEMBLY	STL.	SAS16-CR.70/SA-105
3	1	MECHANICAL LINKAGE	STL.	SAS16-CR.70
4	1	ELECTRIC ACTUATOR (MX-40)	COMM.	LIMITORQUE



EXTERNAL LOADS: 18" VALVE

AXIAL FORCE: 5 KN

TRANSVERSE SHEAR FORCE: 5 KN

VERTICAL SHEAR FORCE: 30 KN

TORSION MOMENT: 5 KN-M

LONGITUDINAL AND CIRCUMFERENTIAL BENDING MOMENTS : EACH 30 KN-

This print is the property of Zimmermann & Jansen, Inc. It must not be traced nor reproduced in any manner nor shall it be submitted to outside parties and competitors for examination without our consent. It shall be used only as a means of reference to work designed or furnished by us.

**CERTIFIED PRINT
Z & J INC.**

ZIMMERMANN & JANSEN, INC.

SEP 15 1999

ISSUED

TOTAL WEIGHT: 7,940 LBS. (3600 Kgs.)

2	FDG	7/15/96			ADDED DIMENSION PER CUSTOMER COMMENTS.	LIS Originator	Date
1	FDG	8/2/96	J.K.	6-29	-	ADDED DIMENSIONS PER CUSTOMER COMMENTS.	
REV.	BY	DATE	CHK'D	DATE	APP'D	DATE	DESCRIPTION
CUSTOMER: SHURTAN GAS CHEMICAL COMPLEX LOCATION: SHURTAN, UZBEKISTAN						 ZIMMERMANN & JANSEN, INC. Houston, Texas, USA	
			DATE	BY			
	DRAWN		5-20-99	FDG			
	CHECKED		5-24-99	J.K.			
	APPR.						
DIMENSIONAL TOLERANCES UNLESS SPECIFIED							
JWO-99054		FRACTION	DECIMAL	ANGLE	BREAK ALL SHARP EDGES		
JOB #		$\pm .015$	X	$\pm .015$	0.015 0.015 45°		
		$\pm .005$	XX	$\pm .010$	SURFACE FIN. 125 AAPH		
		$\pm .005$	XXX				
SCALE: NONE				DWG #	1124-108-01	REV. 2	





ZIMMERMANN & JANSEN, INC.
Houston, Texas, USA

18"-8" DOUBLE DISC THROUGH
CONDUIT VALVE COMBINATION
w/ MECHANICAL LINKAGE
-GENERAL ARRANGEMENT-

SCALE: NONE DWG # V24-108-01 REV 2





BILL OF MATERIAL

ITEM	REQ'D.	DESCRIPTION	MATL.	REFER
1	1	VALVE BODY	STL	V24-106
2	1	BONNET	STL	V24-106
3	2	DISC	STL	V24-106
4	1	GOOGLE PLATE	STL	V24-106
5	2	GUIDE PLATE	C.I.	V24-106
7	1	STEM	S.S.	V24-106
8	2	WEDGE	STL	V24-106
9	1	BALL, 1.575" DIA. (40mm)	S.S.	
10	1	STEM NUT	S.S.	V24-106
11	1	GUIDE BUSHING	C.I.	V24-106
12	1	THRUST WASHER	STL	V24-106
13	1	GLAND FLANGE	STL	V24-106
14	1	PACKING GLAND	C.I.	V24-106
15	1	LANTERN RING	C.I.	V24-106
16	1	SHRINK DISC	C.S.	
17	48	STUD, 1/2"-13UNC-2A X 3 1/8" LG. (ALL THD.)	STL	SA193-G
18	96	HVY. HEX NUT, 1/2"-13UNC-2B	STL	SA194-G
19	2	HVY. HEX NUT, 1/2"-13UNC-2B	STL	SA194-G
20	2	STUD, 1/2"-13UNC-2A X 4" LG. (ALL THD.)	STL	SA193-G
21	8	STUD, 1/2"-13UNC-2A X 2 7/8" LG. (ALL THD.)	STL	SA193-G
22	16	HVY. HEX NUT, 1/2"-13UNC-2B	STL	SA194-G
23	2	HVY. HEX BOLT, 5/8"-11UNC-2A X 2 3/4" LG.	STL	SA193-G
24	2	HVY. HEX NUT, 5/8"-11UNC-2B	STL	SA194-G
25	1	PIPE PLUG, 1/4" NPT HEX HEAD PIPE PLUG	STL	SA193-G
26	10	CUP SPRING, 80mm O.D. X 41mm I.D. X 4mm	S.S.	
27	1	BOTTOM COVER	STL	V24-106
28	2	BLIND FLANGE, 3/4"-150# R.F. PER ANSI B16.5	F.S.	SA-10
29	4	PACKING RING, 7/16" SQ. X 6 9/16" LG. W/ENDS CUT @45°	BRANDED GRAPHITE	J.CRANE 1
30	2	FLAT TYPE GASKET	304SS w/GRAPH	V24-106
31	5	DOWEL PIN	STL	V24-106
32	2	GASKET, 2" O.D. X 1 3/16" I.D. X 1/8" THK.	304SS w/GRAPH	SPIRAL W
34	1	FLOW DIRECTION INDICATOR PLATE w/ (4) DRIVE SCREWS	S.S.	V24-106
39	6	HEX HEAD CAP SCREW, 3/8"-16UNC-2A X 1 3/4" LG.	STL	SA193-G
40	2	PACKING RING, 7/32" X 7/16" X 6 9/16" LG. W/ENDS CUT @45°	BRANDED GRAPHITE	J.CRANE 1

This print is the property of Zimmermann & Jansen, Inc. It must not be traced nor reproduced in any manner nor shall it be submitted to outside parties and competitors for examination without our consent. It shall be used only as a means of reference to work designed or furnished by us.

CERTIFIED PRINT
Z & J INC.

TORQUE NUTS TO
24.3 FT# (33Nm)

15
NS (58Nm)


14 1/4"

17
18
31

ZIMMERMANN & JANSEN, INC.

SEP 15 1999

ISSUED




CUSTOMER: SHURTAN GAS CHEMICAL COMPLEX
LOCATION: SHURTAN, UZBEKISTAN

	DRAWN	DATE	BY
DRAWN	7-16-99	FDG	
CHECKED	8-13-99	J.K.	
APPR.			


DIMENSIONAL TOLERANCES
UNLESS SPECIFIED

IWO-99054	FRACTION	DECIMAL	ANGLE	UNIT
JOB #	$\pm \frac{1}{32}$ XXX	$\pm .015$ $\pm .010$ $\pm .005$	$\pm 0^\circ$	0.01-0.01 45° SURFACE FIN 125 AARH




SCALE: NONE

V24-106-02



SECTION "A-A"



DLV12TM
TAG-NO.: XV 11107
XV 11207
XV 11307

FLUID
PROCESS - DECOCKING:

HYDROCARBONS WITH STEAM AND
OIL-COKE PARTICLES

OPERATING PRESSURE:
250 kPaG
OPERATING TEMPERATURE:
270°C

CORROSION ALLOWANCE:

MEDIUM WETTED PARTS: 1/8" (3mm)

(BODY PASSAGE)

PURGE STEAM WETTED PARTS: 1/16" (1.5mm)

(BODY CAVITY)


DESIGN PRESSURE:
350 kPaG
DESIGN TEMPERATURE:
425°C

STEAM PURGE
OPERATING PRESSURE:
400 kPaG
OPERATING TEMPERATURE:
190°C

THE PURGE STEAM SHOULD BE THROTTLED TO 0.5 barg
ABOVE OPERATING/DECOCKING PRESSURE TO PURGE THE VALVES

DESIGN PRESSURE:
400 kPaG
DESIGN TEMPERATURE:
280°C

INSTALLATION: VERTICAL STEM IN HORIZONTAL LINE




This print is the property of Zimmermann & Jansen, Inc. It must not be traced nor reproduced in any manner nor shall it be submitted to outside parties and competitors for examination without our consent. It shall be used only as a means of reference to work designed or furnished by us.

BILL OF MATERIAL

ITEM	REQ'D.	DESCRIPTION	MAT'L.	REFERENCE
1	1	12" VALVE ASSEMBLY	STL.	SA516-GR.70/SA-105
2	1	ELECTRIC ACTUATOR (MX-10)	COMM.	LIMITORQUE

05
05




ZIMMERMANN & JANSEN, INC.

SEP 15 1999

CERTIFIED PRINT
Z & J INC.

ISSUED



TOTAL WEIGHT: 2,645 LBS. (1200 Kgs.)

REV.	FDG	6/20/99	DATE	CHK'D	DATE	APP'D	DATE	ADDED DIMENSIONS PER CUSTOMER COMMENTS.					
DESCRIPTION													
CUSTOMER: SHURTAN GAS CHEMICAL COMPLEX LOCATION: SHURTAN, UZBEKISTAN													
				DRAWN	5-20-99		BY						
				CHECKED	5-24-99		J.K.						
				APPR.									
				DIMENSIONAL TOLERANCES UNLESS SPECIFIED									
				FRACTION	DECIMAL	ANGLE		BREAK ALL SHARP EDGES 0.01-0.015 45° SURFACE FIN. 125 A.R.H.					
				JWO-99054	X ± .015 XX ± .010 XXX ± .005	± 0.5°							
				JOB #	# 33								
								SCALE: NONE	DWG # V24-107-01	REV: 1			

ABB Group Consorium	ABB Lummus Global Grid
Project: Shurtan Gas Chemical Complex	The approved does not relieve the vendor of his responsibility to meet all requirements of the P.R.
Owner's Project No.: 2300977	<input type="checkbox"/> P: Prepared with Fabrication <input type="checkbox"/> B: Prepared, change as required, revised issue req'd <input type="checkbox"/> C: Not acceptable, to be revised before starting fab. <input type="checkbox"/> F/F: Fabrication info req'd as further direction required <input type="checkbox"/> R/R: Rejects to be re-submitted for review <input type="checkbox"/> S/S: Superseeded <input type="checkbox"/> C/C: Cancelled
Log/Item No.: V24-107 V24-107	
Purchase Order No.: 1062-62H	
RFI doc. code:	
SEC sequence no.	
HQ-CB	
Log Originator	Editor

